



GENERAL NOTES:

1 INSTALL AS REQUIRED BY CONSTRUCTION PLANS.

CONSTRUCTION NOTES:

A VALVE BOX PER C.O.A. STD. DWG. 2326.

B GATE VALVE FL.— FL.

C WATER LINE TO AIR RELEASE IN SIDEWALK.

D C.I./D.I. FL. 90° BEND.

E FL. OUTLET OR C.I./D.I. TEE.

F WATER MAIN.

REVISIONS	CITY OF ALBUQUERQUE
	WATER AIR RELEASE CONNECTION
	DWG. 2344 JANUARY 2003